

## Mercury Thermostat Collection Act of 2008

Contractor Requirements - Those who install heating, ventilation, and air-conditioning components are required to:

- Handle the thermostat in accordance with DTSC regulations (to be adopted by 2012).
- Take the out-of-service mercury-added thermostat to a location bin that is operated in accordance with regulations.

Building Demolition Requirements:

- Remove the out-of-service mercury-added thermostats prior to demolition in accordance with all applicable regulations.
- Take the out-of-service mercury-added thermostat to a location that is authorized to collect out-of-service mercury-added thermostats.