

RECOMMENDED MINIMUM VERIFICATION ANALYSES FOR UNDERGROUND STORAGE TANK LEAKS

For use by Unidocs Member Agencies or where approved by your Local Jurisdiction

TABLE #2
Revised March 1, 1999

<u>HYDROCARBON LEAK</u>	<u>SOIL ANALYSIS</u> (SW-846 Method)		<u>WATER ANALYSIS</u> (Water/Waste Water Method)	
Gasoline (Leaded and Unleaded)	TPHG	8015M or 8260	TPHG	8015M or 524.2/624 (8260)
	BTEX	8260	BTEX	524.2/624 (8260)
	EDB and EDC	8260	EDB and EDC	524.2/624 (8260)
	MTBE, TAME, ETBE, DIPE, and TBA by 8260 for soil and 524.2/624 (8260) for water			
	Total Lead	AA	Total Lead	AA
		--Optional--*		
	Organic Lead	DHS-LUFT	Organic Lead	DHS-LUFT
Unknown Fuel	TPHG	8015M or 8260	TPHG	8015M or 524.2/624 (8260)
	TPHD	8015M or 8260	TPHD	8015M or 524.2/624 (8260)
	BTEX	8260	BTEX	524.2/624 (8260)
	EDB and EDC	8260	EDB and EDC	524.2/624 (8260)
	MTBE, TAME, ETBE, DIPE, and TBA by 8260 for soil and 524.2/624 (8260) for water			
	Total Lead	AA	Total Lead	AA
	--Optional--*			
	Organic Lead	DHS-LUFT	Organic Lead	DHS-LUFT
Diesel, Jet Fuel, Kerosene, and Fuel/Heating Oil	TPHD	8015M or 8260	TPHD	8015M or 524.2/624 (8260)
	BTEX	8260	BTEX	524.2/624 (8260)
	EDB and EDC	8260	EDB and EDC	524.2/624 (8260)
	MTBE, TAME, ETBE, DIPE, and TBA by 8260 for soil and 524.2/624 (8260) for water			
Chlorinated Solvents	CL HC	8260	CL HC	524.2/624 (8260)
	BTEX	8260 or 8021	BTEX	524.2/624 (8260) or 502.2/602 (8021)
Nonchlorinated Solvents	TPHD	8015M or 8260	TPHD	8015M or 524.2/624 (8260)
	BTEX	8260 or 8021	BTEX	524.2/624 (8260) or 502.2/602 (8021)
Waste, Used, or Unknown Oil	TPHG	8015M or 8260	TPHG	8015M or 524.2/624 (8260)
	TPHD	8015M or 8260	TPHD	8015M or 524.2/624 (8260)
	O&G	9070	O&G	418.1
	BTEX	8260	BTEX	524.2/624 (8260)
	CL HC	8260	CL HC	524.2/624 (8260)
	EDB and EDC	8260	EDB and EDC	524.2/624 (8260)
	MTBE, TAME, ETBE, DIPE, and TBA by 8260 for soil and 524.2/624 (8260) for water			
	Metals (Cd, Cr, Pb, Ni, Zn) by ICAP or AA for soil water			
PCB, † PCP, † PNA, CREOSOTE by 8270 for soil and 524/625 (8270) for water				

NOTES:

1. 8021 replaces old methods 8020 and 8010.
2. 8260 replaces old method 8240.
3. Reference: Table B-1 in Appendix B of "Expedited Site Assessment Tools for Underground Storage Tank Sites: A Guide for Regulators" (EPA 510-B-97-001).

* Optional per Regional Water Quality Control Board (Board), but local agency that regulates UST system may require analysis for Organic Lead. Check with your local agency regarding their requirements.

† If found, analyze for dibenzofurans (PCBs) or dioxins (PCP).